अधिशासी अभियन्ता,
खण्ड कार्यालय, उ0प्र0 जल निगम (ग्रामीण), शामली
रेलवे स्टेशन के सामने, बाई पास रोड गली नं0–5 शामली

सेवा में,

प्रबन्धक
एस0डी0एस0 पब्लिक स्कूल
गढी अब्दुल्ला खान (शामली)

पत्रांक: 279/ 103 /37 दिनॉक: 10-3-26

विषयः– जल नमूने की जॉच के सम्बन्ध में।

महोदया,

उपरोक्त विषयक आपके पत्र सं0– शून्य दिनांक 06.03.2026 के क्रम में आपके द्वारा उपलब्ध कराये गये, 01 नग जल नमूने के केमिकल एवं बैक्टीरियोलोजिकल परीक्षण कर, जल नमूने की जॉच रिपोर्ट संलग्न कर आवश्यक कार्यवाही हेतु प्रेषित है।

संलग्नक– जल परीक्षण रिपोर्ट।

भवदीय

10/03/26
(फूल सिंह यादव)
अधिशासी अभियन्ता

Wasar Ali
Manager
S.D.S. Public School
Garhi Abdulla Khan (Shamli)

S.D.S PUBLIC SCHOOL
Principal
GARHI ABDULLA KHAN (SHAMLI)

59 letter C:\Users\up\nl\Desktop\New folder\Report letter current.docx

District Level Water Analysis Laboratory of Uttar Pradesh Jal Nigam (Rural) Shamli

TC-13814

Test Report (Water)

Analysis Report

District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural), Shamli Uttar Pradesh, India

Repot No.	2540	Date:	07/03/2026	Page No. 01
Customer Name	S.D.S.Public School Garhi Abdulla Khan			
Office Name and Address	S.D.S.Public School Garhi Abdulla Khan			
Ref Letter No & date	शून्य Dt-06/03/2026			

Basic Details of Sample

District	Shamli	Block	Thanabhawan
Gram Panchayat	Thanabhawan	Village	Abdulla Khan
Habitation	----------	Location/Site name	S.D.S.Public School Garhi Abdulla Khan
Water Source	Submersible	Sample No.	SML-2540
Quantity of Sample (ml)	1 ltr	Date of Sample Collect.	06/03/2026
Receiving Date	06/03/2026	Sample Collector	Firoz Chaudhary
Sample Depositor	Firoz Chaudhary	Sampling Method	IS 17614 (Part 1):2021
Analysis Strat date	06/03/2026	Analysis completion date	07/03/2026

Technical Data Analysis

S. No.	Analysis Parameter	Units	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5):2021
2	Taste	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 7):2023
3	pH	-	7.57	6.5-8.5	6.5-8.5	IS 3025 (Part 11):2022
4	Turbidity	NTU	0.496	1	5	IS 3025 (Part 10):2017
5	TDS	mg/L	318	500	2000	IS 3025 (Part 16):2023
6	Chloride	mg/L	26.20	250	1000	IS 3025 (Part 32):2019
7	Total Alkalinity	mg/L	206	200	600	IS 3025 (Part 23):2023
8	Total Hardness	mg/L	188	200	600	IS 3025 (Part 21):2019
9	Sulphate	mg/L	21.35	200	400	APHA 24th 4500 SO4 E. Turbidity Method:2023
10	Nitrate	mg/L	6.88	45	45	APHA 24th 4500 NO3 B. UV Spec Method:2023
11	Fluoride	mg/L	0.416	1	1.5	APHA 24th 4500-F C. Electrode Method:2023
12	Iron	mg/L	0.42	1	1	APHA 24th 3500 Fe B. Phenanthroline Method:2023
13	Calcium	mg/L	43.66	75	200	IS 3025 (Part 40):2019
14	Magnesium	mg/L	19.62	30	100	IS 3025 (Part 46):2023

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of send under the stated conditions of measurements.
4. Sample will be stored up to 7 days. (in case of non-perishable items only) from the date of issue of tests report unless.

Prepared by | Reviewed by | Authorized by

Chemist
District Level Water Analysis Laboratory

Manager
S.D.S. Public School
Garhi Abdulla Khan (Shamli)

End of Report

Principal

Laboratory Contact Details: Email-Id: upjnlabshamli@gmail.com, Mobile mo.: +91 9528906867, +91 9917444912

District Level Water Analysis Laboratory of Uttar Pradesh Jal Nigam (Rural) Shamli

Test Report (Water)

Analysis Report

District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural), Shamli Uttar Pradesh, India

Repot No.	2540	Date:	07/03/2026	Page No. 01
Customer Name	S.D.S.Public School Garhi Abdulla Khan			
Office Name and Address	S.D.S.Public School Garhi Abdulla Khan			
Ref Letter No & date	शून्य Dt-06/03/2026			

Basic Details of Sample

District	Shamli	Block	Thanabhawan
Gram Panchayat	Thanabhawan	Village	Abdulla Khan
Habitation	----------	Location/Site name	S.D.S.Public School Garhi Abdulla Khan
Water Source	Submersible	Sample No.	SML-2540
Quantity of Sample (ml)	1 ltr	Date of Sample Collect.	06/03/2026
Receiving Date	06/03/2026	Sample Collector	Firoz Chaudhary
Sample Depositor	Firoz Chaudhary	Sampling Method	IS 17614 (Part 1):2021
Analysis Strat date	06/03/2026	Analysis completion date	07/03/2026

Technical Data Analysis

S. No.	Analysis Parameter	Units	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	E. Coli	CFU/100ml	0	0	0	IS 15185:2016 (RA 2021)
2	Total Coliform	CFU/100ml	0	0	0	IS 15185:2016 (RA 2021)

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of send under the stated conditions of measurements.
4. Sample will be stored up to 7 days. (in case of non-perishable items only) from the date of issue of tests report unless.

Prepared by | **Reviewed by** | **Authorized by**

Chemist
District Level Water Analysis Laboratory
U.P. Jal Nigam (Rural)

Wasim Ali
Manager
S.D.S.Public School
Garhi Abdulla Khan (Shamli)

S.D.S PUBLIC SCHOOL
Principal

End of Report

Laboratory Contact Details: Email-Id: upnlabshamli@gmail.com, Mobile no.: +91 9528906867, +91 9917444912